


Optimization models for the combination of heat pumps with solar thermal in domestic applications



Jacob van Berkel
Entry Technology Support BV
Assigned by Netherlands Enterprise Agency (RVO)

1

Basic questions:

1. What is the Energy Performance?
2. What are the advantages?
3. What are the costs?
4. How can they be fitted into an Energy Performance Standard ?

2

Archetype system





Features:

1. 20-40 GJ heating
2. 14 GJ DHW
3. ~ 2 x 20 m² roof
4. Zero energy ?

3

Calculation method: Hourly

1. Hourly method , 8760 sequential hours/year. Explicit time-integration $t_n \Rightarrow t_{n+1}$.



Hourly values of ambient temperature and solar radiation, as opposed to monthly average values (red line).


2. As simple as monthly values, more accurate.
3. Option to incorporate thermal capacities.
4. Conform : prEN15316-5

4

Weather-input according to NEN5060

1. On an hourly basis:


- Solar radiation: **G** [W/m²].
- Dry bulb temperature **T** [°C].
- Relative humidity **RV** [%].
- Absolute moist content **H** [gr/kg].
- Saturated vapour pressure **Ps** [Pa].
- Wind speed **U** [m/s].
- Wind direction **D** [grd].
- Cloud fraction **N** [%].
- Precipitation **R** [mm].
- Air enthalpy **h** [kJ/kg].



5

Soil temperature


1. Medium temperature (@ evaporator) according to NEN 7120, appendix Q



6


Heat Pump- Performance

1. COP and Power, bilinearly depending on evaporator and condenser temperatures



7

Ambient heat exchanger (solar collector)




$$\dot{Q} = \eta_0 G - c_1 (T_m - T_a) - c_2 (T_m - T_a) |T_m - T_a| + c_3 u (T_m - T_a) + c_4 (E_L - \sigma T_m^4) - c_5 \frac{dT_m}{dt} - c_6 u G + c_7 (2.8 - 3.0 u) (v_a - v_{sat}(T_m)) + c_8 (\sigma T_b^4 - \sigma T_a^4) + c_9 m_{wat} C_{p, wat} (T_{wat} - T_m)$$

Ref. Bunea, 2015 conform EN12975

8

Heating (H) demand


1. Distribution over a year, according to degree-hours (ambient temperature).
2. Maximum heating system temperatures according to NEN 7120



9


DHW-heating (W)

1. Draw-profile #4 (49 draws), recalculated to hourly values.



10

System Control



Mode	Description	Schematic
"0"	Collector not in operation. No- or negative power at temperatures equal to ground source.	
"1"	Collector positive- but insufficient power at ground source temperature, support from ground source needed.	
"2"	Collector can provide necessary power, but not at required space heating- or DHW temperature.	
"3"	Collector can provide necessary power at spacing or DHW-temperature (bypass).	

XLS-calculation tool

1. Cockpit (input/output)

The spreadsheet displays the following data:

Specifications Heat Pump-EN 14511 Test Results			
Tcond,out	Tcond,in	Tevap,in	Tevap,out
35,00	20,00	0,00	-5,00
45,00	40,00	0,00	-5,00
45,00	40,00	10,00	5,00
COP	P(CR)		
5,00	4500		
4,00	4000		
5,00	4500		

Hot water tank		
Tank Volume	180	[Liter]
Set temperature hotup	60	[°C]
Tank ambient temperature	20	[°C]
Heat loss factor	0,75	[W/K]
Set point max tank temperature	80	[°C]
Set point heat pump on	0,50	[-]
Set point E-heater	0,25	[-]
Annual Hot Water Demand	7,5	[GJ]



Space heating demand		
Threshold temperature	12	[°C]
CH-supply temperature (Δ-18°C)	30	[°C]
Space heating load	45,5	[GJ]

Auxiliary Energy		
Solar circulation pump	50	[W]
CH-circulation pump (H, W)	50	[W]
System control	5	[W]


Results		
Qsol	22802	[kWh]
QE	10913	[kWh]
Qh dis,nren	45,5	[GJ]
Qw dis,nren +Qw dis,ls	7,5	[GJ]
Enp,h + Wh,aux	14,1	[GJ]
Enp,w + Ww,aux	1,8	[GJ]

Elektrische bijstook		
Benodigd vermogen (H)	9	[kW]
Benodigd vermogen (W)	0	[kW]

Waux (hulpenergie) [uren] [Wh]		
Systeemregeling	6760	43800
Circ. zon H	4835	241750
Circ afg. H	4835	241750
Totaal H		827300
		1888,3
Circ. zon W	496	24800
Circ afg. W	496	24800
Totaal W		49600
		178,8




Validation with PolySum



System performance, assuming: 25 m² collector orientated south, 5 kW heat pump, 40 GJ annual heating load, 13 GJ annual hot water demand, Dutch reference year.

15

Insight in collector temperatures




Sample system. The red line give the mean temperature of the collector. The blue solid line is the ambient air temperature.

16

Marginal system performance and costs

Assuming:


- A particular (6 kW) heat pump and constant load (H: 40 GJ and DHW: 13 GJ)
- 25 ct/kWh electricity costs; 100 €/m² collector costs and 10% annual amortization)



Sample system: The red line indicates annual generation efficiency; The blue line the annual electricity + collector depreciation costs

17

Declaration of conformity



18

Conclusions

1. For The Netherlands: Small is Beautiful !
2. Economical optimal size, for typically Dutch conditions:
 - a) Small heat pump < 5 kW
 - b) Small DHW-tank < 200 litre
 - c) Ambient collector < 10-20 m²
3. Costs-competitiveness to be determined
4. First declaration of conformity now underway

19

Further issues

1. Improve model by integration of single-node thermal building capacity (easy due to hourly time stepping)
2. Evaluate costs-effectiveness

20

Thanks!

More information:

J. van Berkel

Entry Technology Support BV

entry@xs4all.nl

+31 6 228 70 615

21

Poll:

1. The best (most costs effective, quiet) exchanger of ambient heat is:
 Uncovered, roof integrated collector BTES Fan-coil
2. For large scale implementation, heat pumps will be the heat generator in the built environment, in combination with district :
 Electricity (exclusively) Heat + electricity

22